

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO 10871

1. OWNER RAY & HELEN HYDE ADDRESS AT WELL LOCATION  
1105 AMARILLO  
GARDNERVILLE, NEVADA  
 2. LOCATION NW 1/4 SE 1/4 Sec 17 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. NONE 27-664-05 CHAMBERS FIELD  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN WITH SMALL TO MEDIUM BULLDERS &amp; CLAY</u>		<u>0</u>	<u>11</u>	<u>11</u>
<u>GRAVELS, SAND &amp; 6" BUCKLE FIRST WATER AT 50 FEET</u>	<input checked="" type="checkbox"/>	<u>11</u>	<u>90</u>	<u>79</u>
<u>CLAY SEAMS WITH SAND &amp; GRAVEL</u>		<u>90</u>	<u>94</u>	<u>4</u>
<u>SMALL TO MEDIUM GRAVEL WITH FINE TO COURSE SAND</u>	<input checked="" type="checkbox"/>	<u>94</u>	<u>118</u>	<u>24</u>
<u>CLAYSEAM &amp; GRAVEL</u>		<u>118</u>	<u>120</u>	<u>2</u>
<u>T.I.D. 120 FEET</u>				

8. WELL CONSTRUCTION  
 Diameter 1 1/2 inches Total depth 120 feet  
3/4 inches  
 Casing record 6 5/8" steel  
 Weight per foot 11.7 Thickness 1.56  

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CONCRETE  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 120 feet  
 Perforations:  
 Type perforation Facility Mill Slot  
 Size perforation 3/32" x 3"  
 From 95 feet to 115 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started OCT 21, 1988  
 Date completed OCT 24, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>FLUSHED WITH CLEAN WATER TO GRAVEL PACK &amp; TO REMOVE DRILL MUD. BLEW 30 GPM WITH 250 PSI AIR TO DEVELOP FOR 2 HOURS FROM 100 FEET</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Flow 30 F G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP CO Contractor  
 Address CARSON CITY, NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1972  
 Signed Quinton Batts  
 By driller performing actual drilling on site or contractor  
 Date OCT 24, 1988