

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 10976

PRINT OR TYPE ONLY

1. OWNER JAMES GALORBEZGA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
Gardnerville, Nevada Gardnerville, Nevada
 2. LOCATION SW 1/4 SE 1/4 Sec. 17, T. 12.0 N. R. 2.0 E. Douglas County
 PERMIT NO. NONE 27-664-13 Chambers Field
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/>	Stock <input type="checkbox"/> Other <input type="checkbox"/> <u>Hand</u>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden with gravel & Clay</u>		<u>0</u>	<u>9</u>	<u>0</u>
<u>Gravels with Boulders</u>	<u>r</u>	<u>9</u>	<u>91</u>	<u>82</u>
<u>Brown Clay seam gravel with fine to coarse sand</u>	<u>✓</u>	<u>91</u>	<u>97</u>	<u>6</u>
<u>Brown to tan Clay seam</u>		<u>111</u>	<u>117</u>	<u>6</u>
<u>Gravel with Clean sand laden with clean water</u>	<u>✓</u>	<u>117</u>	<u>143</u>	<u>26</u>
<u>T.D. 143 Feet</u>				

8. WELL CONSTRUCTION

Diameter 1 1/2 to 60 inches Total depth 143 feet
8 3/4 inches
 _____ inches
 Casing record Steel 6 3/8" O.D.
 Weight per foot 11.7 Thickness .156
 Diameter From To
6 inches 7.2 feet 143 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Concrete
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 143 feet
 Perforations: Factory Mill slot
 Type perforation 3/32" x 3"
 Size perforation 118 feet to 138 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 12 feet below land surface
 Flow 30+ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO Contractor
 Address CARSON CITY, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 23795
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
 Signed Quentin Butts
 By driller performing actual drilling on site or contractor
 Date Oct 30, 1988

Date started Oct 17, 1988
 Date completed Oct 19, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Finished with clear water to remove drill mud & gravel pack. Sealed well & developed with 250 PSI air for 2 hours</u>			

BAILER TEST

Draw down	feet	hours
<u>_____</u>	<u>_____</u>	<u>_____</u>
<u>_____</u>	<u>_____</u>	<u>_____</u>
<u>_____</u>	<u>_____</u>	<u>_____</u>