WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30469
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10860

1. OWNER Robert Brody
MAILING ADDRESS 2341 Main St Genoa Nevada
ADDRESS AT WELL LOCATION 2341 Main St Genoa Nevada

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 17-084-23 Parcel No. | None Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN & TOPSOIL		0	17	17
BOULDERS, GRAVEL WITH HEAVY DARK CLAYS		17	85	68
GRAVELS WITH SMALL TO 2" ROCK, FINE SAND	✓	85	120	35
T.D. 120 FT				

Date started OCT 10, 1988
Date completed OCT 11, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
FLUSHED MUD FROM WELL WITH CLEAN WATER & GRAVEL PACKED DEVELOPED WELL WITH AIR FOR 2 HOURS 35+ GPM FROM 110 FEET			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 56 inches Total depth 120 feet
9 1/4 inches
____ inches
Casing record 6 5/8" STEEL
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 120 feet

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3/32" X 3"
From 95 feet to 116 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 30 feet below land surface
Flow 35+ G.P.M. ____ P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address CARSON CITY, NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] By driller performing actual drilling on site or contractor
Date OCT 14, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627