

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

Edd Furgerson  
 Stanton Park Development

NOTICE OF INTENT NO. 9192

1. OWNER Stanton Park Development ADDRESS AT WELL LOCATION 5049 Highway 50 East  
 MAILING ADDRESS P. O. Box 1161  
Carson City, Nv 89702

2. LOCATION NW 1/4 NW 1/4 Sec. 11 T. 15 N/S R. 20 E Carson County

PERMIT NO. W-282 Issued by Water Resources Parcel No. 8-371-8 Supervision Name See legal 3/26/88

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard pan fill		0	2	2
Brown clay and gravels		2	11	9
Red clay & volcanic gravels with some D.G.		11	54	43
Purple brown green yellows white volcanic rock				
Brown clay with green red yellow		54	104	50
Green brown fractured volcanic rock		104	127	23
Sand		127	132	5
Fractured rock green with traces of clay		132	157	25
Brown clay with green yellow brown sands & gravels		157	194	37
Fractured volcanic rock with some clay		194	298	144
Brown clay with some sands		298	307	9

8. 16" to 50' WELL CONSTRUCTION  
 Diameter 12 inches Total depth 307 feet  
 Casing record 12 3/4 inch 8 5/8 inch  
 Weight per foot 25.22/ 20.16 Thickness .201

Diameter	From	To
12 inches	0	50
8 inches	+2	305
_____ inches	_____	_____

Surface seal: Yes  No  Type neat cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 0 feet to 307 feet

Perforations:  
 Type perforation Roscoe-Moss wire wound screen  
 Size perforation .100

From	To
120	160
180	210
230	300
_____	_____
_____	_____

Date started 8/29/88, 19\_\_\_\_  
 Date completed 9/17/88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift for	<u>15 1/2 hours</u>	<u>to clean</u>	<u>and develop</u>
Test pumped	<u>by others</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL PER TELECON W/OWNER  
 Static water level 16 feet below land surface 10/14/88  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall