

OFFICE USE ONLY
 Log No. 30478
 Permit No. _____
 Basin 2-103
 NOTICE OF INTENT NO. 6316

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER City of Carson ADDRESS AT WELL LOCATION East 5th Street
 MAILING ADDRESS Carson City, Nevada Carson City Nevada

2. LOCATION SW 1/4 SW 1/4 Sec 14 T 15 N/S R. 20 E Carson City County
 PERMIT NO. n/a none none
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	7	
Decomposed Granite		7	17	
Clay		17	18	
Decomposed Granite		18	23	
Gravel		23	26	
Light Brown Clay		26	35	
Sand		35	42	
Gravel & Sand		42	60	
Brown Clay		60	65	
Sand		65	83	
Lt. Brown Clay		83	90	
Gray Sandy Clay		90	100	
Fine Brown Sand		100	110	
Brown Clay		110	115	
Fine Brown Sand		115	120	
Green Sandy Clay		120	130	
Lt. Brown Clay		130	138	
Green DG		138	140	
Green Sandy Clay		140	155	
Green & White DG		155	165	
Green Sand		165	170	
Green Sand w/DG		170	185	
Course Dg (white)		185	192	
Green Clay & Mica		192	200	
Brown & Green Clay		200	210	
Green & Gray Clay		210	225	
Gray clay w/Lavender Rock		225	235	

8. WELL CONSTRUCTION
 Diameter 13 inches Total depth 20 feet
7 7/8 inches 255'
 inches
 Casing record Steel & PVC
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>8</u> inches	<u>1</u> feet	<u>20</u> feet
<u>2</u> inches	<u>0</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type 0-50' Neat Cement
 Depth of seal 0-50' feet
 Gravel packed: Yes No
 Gravel packed from 50'-84' feet to 150'-255' feet
 Perforations:
 Type perforation Mill Slot
 Size perforation .030"
 From 160 feet to 190 feet
 From 230 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-14-88, 19_____
 Date completed 9-23-88, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

air
 WATER TEST
 G.P.M. Approx. 10 Draw down 160 feet 8 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level _____ feet below land surface
 Flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kimberly Builders
 Contractor
 Address Reno, Nevada
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 8595
 Nevada contractor's driller's number issued by the Division of Water Resources N/A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 10-11-88

