

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6315

1. OWNER City of Carson ADDRESS AT WELL LOCATION East 5th Street
 MAILING ADDRESS Carson City, Nevada Carson City, Nevada

2. LOCATION NE 1/4 SE 1/4 Sec. 15 T. 15 N/S R. 20 E Carson City County
 PERMIT NO. N/A none none
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Gravel		0	5	
Sand & Gravel		5	10	
Brown Clay		10	27	
Gravel		27	29	
Brown Sand		29	30	
Decomposed Granite		30	32	
Gray Clay		32	35	
Gravel		35	44	
Gray Clay		44	49	
White DG		49	60	
White Clay		60	66	
Decomposed Granite		66	70	
thin layers of clay-DG		70	80	
Green Sandy Clay		80	95	
Gray Clay		95	110	
White & Green DG		110	125	
Green Sandy Clay		125	140	
Green DG & Clay		140	150	
Green Sandy Clay		150	160	
Green Clay & DG		160	165	
White DG w/little Cl.		165	185	
Brown Clay		185	195	
Multi-colored Clay		195	210	
Lavender Rock		210	220	
Multi-colored Rock		220	225	
Lt. Brown Clay & Rock		225	235	
Multi-colored Rock		235	244	

8. WELL CONSTRUCTION
 Diameter 13 inches Total depth 20' feet
7 7/8 inches 80'
6 3/4 inches 244' TD
 Casing record Steel & PVC
 Weight per foot _____ Thickness .188-Sch 40

Diameter	From	To
<u>8</u> inches	<u>1</u> feet	<u>20</u> feet
<u>2</u> inches	<u>0</u> feet	<u>244'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Neat Cement
 Depth of seal 0'-40' & 88'-150' feet
 Gravel packed: Yes No
 Gravel packed from 40-88' feet to 150'-244' feet
 Perforations:
 Type perforation Mill Slot
 Size perforation .030
 From 160' feet to 190' feet
 From 210' feet to 220' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-23-88, 19____
 Date completed 10-6-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

air
 BAKER TEST
 G.P.M. Approx. 10 Draw down 160 feet 8 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level _____ feet below land surface
 Flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kimberly Builders Contractor
 Address Reno, Nev. Contractor
 Nevada contractor's license number 8595
 issued by the State Contractor's Board
 Nevada contractor's driller's number N/A
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1418
 Division of Water Resources, the on-site driller
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 10-11-88