WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30489
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9670

1. OWNER Andy Harold
MAILING ADDRESS 9300 Pat Circle
Stagecoach, NV 89429
ADDRESS AT WELL LOCATION same

2. LOCATION NW ¼ SE ¼ Sec. 3 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. (Issued by Water Resources) 15-411-85 (Parcel No.) Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & clay		0	4	4
gravel, sand & clay		4	7	3
clay		7	12	5
alluvial fill &				
clay stratas		12	40	28
clay		40	42	2
alluvial fill		42	60	18
alluvial fill & rock		60	68	8
alluvial fill		68	75	7
alluvial fill & clay		75	85	10
alluvial fill, rock &				
clay		85	90	5
alluvial fill & rock		90	95	5
alluvial fill, rock				
& clay		95	102	7
alluvial fill & rock		102	122	20
clay & fill		122	130	8
fill & clay		130	140	10
fill & clay		140	155	15
fill & clay		155	160	5
fill & rock	X	160	181'6"	21'6"

Date started 6-18, 1988
Date completed 6-23, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 40 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 182'6" feet
inches
inches
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	+1 feet	181'6" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 181'6" feet

Perforations:
Type perforation Sawed
Size perforation 3/32" x 3" x 6 rows
From 160 feet to 181'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 81 feet below land surface
Flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros. Drilling (Contractor)
Address 162 N. Bybee Ln. Yerington NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 870
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 870
Signed Bill Ogden (By driller performing actual drilling on site or contractor)
Date 10/5/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627