WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30507
Permit No.
Basin 101 Carson Desert

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER BOB MILNE
MAILING ADDRESS 11655 Fulkerson Rd.
Fallon, Nevada 89406

ADDRESS AT WELL LOCATION
11655 Fulkerson Rd.

2. LOCATION SE¼SW ¼ SW SW ¼ Sec. 8 T 19 N/S R. 27 E. MDM Churchill County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & sandy clay		0	10	10
Fine to medium gravel		10	20	10
Coarse sand to fine gravel		20	50	30
Clay		50	60	10
Clay w/ thin layers of sand		60	80	20
Clay		80	83	3
Coarse sand & fine gravel		83	105	22

Date started July 29, 19 88
Date completed July 29, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift	50 - 75		2

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9 - 7/8 inches Total depth 105 feet
..... inches
..... inches
Casing record 6 - 5/8 inch O.D. X 3/16 inch wall
Weight per foot 12.92 Thickness

Diameter	From	To
6 inches	+1 feet	105 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement sand grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 105 feet
3/8 inch minus well rock

Perforations:
Type perforation milled
Size perforation 1/8 inch X 3 inch
From 85 feet to 105 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHARLES SARGENT IRRIGATION INC. (Contractor)
Address 9955 No. Virginia St. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 31, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627