

OFFICE USE ONLY  
 Log No. 30508  
 Permit No. 51359  
 Basin 101-CARSON DESERT

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER BOB MILNE ADDRESS AT WELL LOCATION 11655 Fulkerson Rd.  
 MAILING ADDRESS 11655 Fulkerson Rd. 11655 Fulkerson Rd.  
Fallon, Nevada 89406

2. LOCATION SE 1/4 SW 1/4 & SW 1/4 Sec. 8 T 19 S R. 27 E MDM Churchill County  
 PERMIT NO. 51359 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & sandy clay		0	10	10
Coarse sand to medium gravel		10	53	43
Clay w/ thin layers of sand		53	80	27
Clay		80	83	3
Coarse sand & fine gravel		83	114	31
Blue clay & fine sand	XX	114	149	35
Fine gravel & coarse sand	XX	149	166	17
Clay		166	173	7
Coarse sand	XX	173	180	7
Fine to medium gravel	XX	180	236	56
Clay		236	240	4

8. WELL CONSTRUCTION

Diameter 22 inches Total depth 240 feet

Casing record 16 inch O.D. X 1/4 inch wall  
 Weight per foot 42.05 Thickness \_\_\_\_\_

Diameter	From	To
<u>16</u> inches	<u>+1</u> feet	<u>240</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement sand grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 240 feet  
3/8 inch minus well rock

Perforations:  
 Type perforation Milled  
 Size perforation 1/8 inch X 3 inch  
 From 120 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started August 3, 1988  
 Date completed August 6, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Airlift</u>	<u>600</u>		<u>3</u>

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 60 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CHARLES SARGENT IRRIGATION INC.  
 Contractor  
 Address 9955 No. Virginia St.  
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada contractor's driller's number issued by the Division of Water Resources 1391  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1482  
 Signed Charles Sargent  
 By driller performing actual drilling on site or contractor  
 Date August 31, 1988