

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 11677

1. OWNER CROMWELL CONSTRUCTION ADDRESS AT WELL LOCATION 1231 YUCCA LANE
 MAILING ADDRESS 1195 CLYDE JR ROAD FALLON, NV 89406
 FALLON, NV 89406

2. LOCATION SE 1/4 NW 1/4 Sec. 8 T 19 N R 29 E CHURCHILL County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	5	5
CLAY		5	13	8
SAND	X	13	26	13
BLK CLAY, SILT & SAND		26	55	29
CLAY		55	76	21
SAND, CLAY LAYERS	X	76	95	19
GRAY CLAY	X	95	102	7
GRAY SAND	X	102	120	18
CLAY	X	120	132	12
SAND	X	132	160	28
CLAY	X	160	185	25
SAND	X	185	196	11
CLAY		196	204	8
SAND & GRAVEL	X	204	224	20

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 224 feet
 _____ inches
 _____ inches
 Casing record 6 5/8 X 224
 Weight per foot 12.9 Thickness .188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>224</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation MACHINE SLOT
 Size perforation 3/32 X 3
 From 212 feet to 220 feet
 From _____ feet to _____ feet

Date started OCTOBER 15, 1988
 Date completed OCTOBER 18, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN @ 60 GPM			

9. WATER LEVEL

Static water level 15 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 61 °F Quality UNKWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
 Address P.O. BOX 888 FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada contractor's driller's number issued by the Division of Water Resources 772
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date OCTOBER 19, 1988

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____