

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11690

PRINT OR TYPE ONLY

1. OWNER DAN & PEGGY PRISBREY ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 2720 Valley View 7670 Tamra
Reno, NV 89506 Reno, NV 89506
2. LOCATION SE 1/4 Sec. 3 T. 20N. N/S R. 19 E. Washoe County
PERMIT NO. _____ Golden Valley Subdivision Name
Issued by Water Resources Parcel No. _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other Air _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------|--------------|------|-----|------------|
| Top soil | | 0 | 2 | 2 |
| Decomposed granite | | 2 | 44 | 42 |
| Granite | | 44 | 53 | 9 |
| Weathered granite softer | | 53 | 145 | 92 |
| " " med. | | 145 | 191 | 46 |
| " " soft | | 191 | 201 | 10 |
| " " harder | | 201 | 210 | 9 |
| Broken & fractured granite | X | 210 | 226 | 16 |
| Granite | | 226 | 233 | 7 |
| Broken & fractured granite | X | 233 | 236 | 3 |
| Granite | | 236 | 245 | 9 |
| Broken & fractured granite | X | 245 | 263 | 18 |
| Granite | | 263 | 276 | 13 |
| Broken & fractured granite X? | | 276 | 280 | 4 |

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 280 feet
Casing record 280' steel casing installed.
Weight per foot _____ Thickness .156
Diameter 6 5/8 inches From 0 feet To 280 feet
Surface seal: Yes No Type cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 280 feet
Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 207 feet to 267 feet

Date started 9-27-88, 19____
Date completed 9-29-88, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
Static water level 180 feet below land surface
Flow 25 G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370, Reno, NV 89510 Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor
Date September 30, 1988