

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11698

PRINT OR TYPE ONLY

1. OWNER LEO L. WHEATLEY ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 15 Sierra View Sierra View
Reno, NV 89506 Reno, NV 89506
2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. 81-140-26 Cold Springs
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay w/some gravels		0	16	16
Fine brown sand		16	18	2
Brown clay		18	33	15
Soft zone (NO WATER)		33	34	1
Brown clay		34	60	26
Soft zone (NO WATER)		60	63	3
Brown clay		63	98	35
Brown sandy clay w/some gravels		98	128	30
Soft zone	X	128	134	6
Brown sandy clay		134	135	1
Volcanic rock		135	154	19
Fracture zone	X	154	159	5
Volcanic rock		159	162	3
Fracture zone	X	162	165	3
Brown & gray volcanic rock		165	175	10

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 175 feet

Casing record 175' steel casing installed

Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>175</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement

Depth of seal _____ feet

Gravel packed: Yes No

Gravel packed from 50 feet to 175 feet

Perforations:

Type perforation factory sawed slot

Size perforation 3/32 x 3 x 6 around

From 129 feet to 169 feet

From _____ feet to _____ feet

Date started 10-31-88 19____

Date completed 10-31-88 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 99 feet below land surface

Flow 25 G.P.M. _____ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.
Contractor

Address P.O. box 12370, Reno, NV 89510
Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada contractor's driller's number issued by the Division of Water Resources 908

Nevada driller's license number issued by the Division of Water Resources, the on site driller 923

Signed [Signature]
By driller performing actual drilling on site or contractor

Date November 2, 1988

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours