WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30534
Permit No. 52089
Basin G-84

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10854

1. OWNER RENO SPARKS INDIAN COLONY
MAILING ADDRESS 15 A RESERVATION ROAD
RENO, NV 89502

ADDRESS AT WELL LOCATION HUNGRY VALLEY

2. LOCATION SE ¼ NW ¼ Sec. 4 T. 21 N/S R. 20 E. WASHOE County
PERMIT NO. W-278 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & GRAVEL		0	3	3
GREEN CLAY		3	6	3
BROWN CLAY		6	38	32
DK GREEN CLAY	X @62	38	135	97
DK GRN CLAY & GRAV		135	150	15
DK GRN CLY & SM GVL	X	150	280	130
GRY GRN CLY & GVL		280	305	25
GRN & BRN CLY & SAND	X	305	326	21
GRN CLAY & BLDRS	X	326	328	2
GRN & BRN CLY & ROCK	X	328	360	32
GRY CLY, SND & ROCK	X	360	388	28
HARD GRY CLY & ROCK	X	388	450	62

Date started JULY 28, 1988
Date completed COTOBER 1, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	40	275	2½

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 16 inches Total depth 440 feet
..... inches
..... inches
Casing record 10 3/4 X 440
Weight per foot 28.04 Thickness 250

Diameter	From	To
10 3/4 inches	0 feet	440 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 330 feet to 430 feet

Perforations:
Type perforation STAINLESS STEEL SCREEN
Size perforation 30 SLOT
From 375 feet to 430 feet
From 345 feet to 365 feet
From 325 feet to 335 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 27 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 62 °F Quality UNKWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources #772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date OCTOBER 10, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627