

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9185

1. OWNER Tom & Kathy Stoneburner ADDRESS AT WELL LOCATION
 MAILING ADDRESS P. O. Box 2626 1955 Piute Creek
 Sparks, Nv 89432 Lot 17.2.2.7
 2. LOCATION SE 1 NW 1/4 Sec. 17 T. 22 N/S R. 22 E. Washoe County
 PERMIT NO. 77-310-14 - Palomino Valley
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light brown hardpan		0	3	3
Red volcanic clay & gravels		3	15	12
Red clay		15	32	17
Green red purple yellow fractured rock	82 110 148	32	178	146
T.D. 178				

8. 10" - 55' WELL CONSTRUCTION

Diameter 6 5/8 inches Total depth 178 feet

Casing record 6 5/8" inches
 Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	178 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type grout
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 178 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 138 feet to 158 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Date started 9/21/88, 19...
 Date completed 9/22/88, 19...

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean & develop.			

BAILER TEST

G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours

9. WATER LEVEL

Static water level 50 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132
 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511

Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 9/28/88