WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 30540
Permit No.
Basin 7-99

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6326

1. OWNER Jim Stewart
MAILING ADDRESS 1374 Antelope Valley Rd.
Reno, Nevada

ADDRESS AT WELL LOCATION Vacant
45 Clydesdale
Red Rock Nevada

2. LOCATION nw ¼ sw ¼ Sec. 32 T. 24 (N)/S R. 18 E. Washoe County
PERMIT NO. N/A (Issued by Water Resources) 078-302-29 (Parcel No.) Rancho Haven Estates (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fine Sand | | 0 | 6 | |
| DG w/green clay | | 6 | 40 | |
| DG w/brown clay | | 40 | 98 | |
| fractured DG | | 98 | 140 | |
| DG w/brown clay | | 140 | 155 | |

Date started 10-4-88, 19
Date completed 10-6-88, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

Air ~~BAILER~~ TEST
G.P.M. Approx. 40 Draw down 140 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 155 feet
inches
inches
Casing record 6 5/8" O.D.
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 inches | -1 feet | 155 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type Neet Cement
Depth of seal 50'+ feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 155' feet

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 115 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Artision feet below land surface
Flow 3 gpm G.P.M. Approx. 20 P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H and M Drilling (Contractor)
Address P.O. Box 18507 Reno, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020417
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1037
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-12-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627