

OFFICE USE ONLY  
 Log No. 30543  
 Permit No. 7-94  
 Basin 7-94

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8128

PRINT OR TYPE ONLY

1. OWNER James Kuta ADDRESS AT WELL LOCATION 16500 Red Rock Rd.  
 MAILING ADDRESS 607 B Trail Drive 16500 Red Rock Rd.  
Reno, Nevada 89506 Reno, Nevada  
 2. LOCATION NW 1/4 NE 1/4 Sec. 9 T. 23 (N/S R. 19 E Washoe County  
 PERMIT NO. N/A 078-222-08 Rancho Haven  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	30	
Granite Stringer		30	32	
Fine Sandy Clay		32	190	
Brown Clay		190	193	
Fine Sandy Clay		193	396	
Decomposed Granite		396	430	
Sandy Clay		430	500	
Decomposed Granite		500	550	

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 70 feet  
8 3/4 inches 550'  
 Casing record 6 5/8" O.D. Steel  
 Weight per foot \_\_\_\_\_ Thickness .156  

Diameter	From	To
<u>6</u> inches	<u>-1</u> feet	<u>550</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50' + feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 550 feet  
 Perforations:  
 Type perforation Mill Slot  
 Size perforation 1/8" x 3"  
 From 470 feet to 530 feet  
 From 370 feet to 430 feet  
 From 110 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-14-88 19\_\_\_\_  
 Date completed 10-29-88 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air ~~BACK~~ TEST  
 G.P.M. Approx. 25 Draw down 550 feet 4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 20' feet below land surface  
 Flow none G.P.M. none P.S.I. \_\_\_\_\_  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name H And M Drilling  
 Address P.O. Box 18507 Reno, nev  
 Nevada contractor's license number 020417  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number \_\_\_\_\_  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1418  
 Division of Water Resources, the on-site driller  
 Signed Bruce Miller  
 By driller performing actual drilling on site or contractor  
 Date 10-31-88