WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 30545
Permit No.
Basin 53

WELL DRILLERS REPORT

PRINT OR TYPE ONLY — Please complete this form in its entirety

1. OWNER MERIT FOR T.S.G.M.C.
MAILING ADDRESS

NOTICE OF INTENT NO.
ADDRESS AT WELL LOCATION Tonkin Springs Man Camp

2. LOCATION SW ¼ SW ¼ Sec. 36 T. 24 N/S R. 49 E M.D.B.&M. Eureka County
PERMIT NO. Mainus #C69 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel-sand	—	0	130	130
gravel-sand	30	130	160	30
clay-sand-gravel	90	160	250	90
gravel-sand-clay	—	250	290	40
limestone	[illegible]	290	300	10

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 300 feet
Casing record 300 ft.
Weight per foot Thickness

Diameter	From	To
10 inches	0 feet	50 feet
6 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 50 ft. feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 ft. feet to 300 feet

Perforations:
Type perforation slot
Size perforation 3/16
From 100 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow 110 G.P.M. P.S.I.
Water temperature 50 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Austin Corporation (Contractor)
Address Box 894, Elko, Nev. (Contractor)
Nevada contractor's license number 21754
Nevada contractor's drillers number
Nevada driller's license number 802
Signed Everett O. Austin (Actual Driller) (Contractor)
Date 10-1-88

Date started 9-1, 1988
Date completed 9-29, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1700	110	30 ft	72 hrs

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434