

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 101639

PRINT OR TYPE ONLY

1. OWNER Dore & ANN FLOCHER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Lamelle Wayack _____
 2. LOCATION NW 1/4 Sec 30 T 33 N/S R 57 E Elko County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name Hipparelli Estate

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------------|--------------|-----------|-----------|------------|
| <u>Sand</u> | | <u>0</u> | <u>5</u> | |
| <u>cemented gravel</u> | | <u>5</u> | <u>7</u> | |
| <u>brown sandy clay</u> | | <u>7</u> | <u>10</u> | |
| <u>H brown clay</u> | | <u>10</u> | <u>25</u> | |
| <u>white to tan clay</u> | | <u>25</u> | <u>35</u> | |
| <u>dark grey clay</u> | | <u>35</u> | <u>45</u> | |
| <u>tan to white clay</u> | | <u>45</u> | <u>70</u> | |
| <u>sands/gravel - flowing water</u> | | <u>70</u> | <u>90</u> | |

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 90 feet
 _____ inches
 _____ inches
 Casing record 90' 6" x 1 1/2"
 Weight per foot _____ Thickness _____

| Diameter | From | To |
|--------------|------------|------------|
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type Cement
 Depth of seal 0-50 feet
 Gravel packed: Yes No
 Gravel packed from 90 feet to 50 feet
 Perforations:
 Type perforation down hole perf.
 Size perforation 4 rows 10 of 106 per foot
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 10/17 1935
 Date completed 10/19 1935

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-------------|------------------|
| | | <u>1.15</u> | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 10 feet below land surface
 Flow G.P.M. 15 P.S.I.
 Water temperature _____ °F Quality _____

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RD Reynolds Contractor
 Address PO Box 403 Wells NV Contractor
 Nevada contractor's license number 014410 issued by the State Contractor's Board
 Nevada contractor's driller's number 1390 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1585
 Signed Russell Baker 1585 By driller performing actual drilling on site or contractor
 Date 10/19/35