CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 32367 (30575)
Permit No.
Basin 4-69

NOTICE OF INTENT NO. 7303

1. OWNER: Jim Delaney
MAILING ADDRESS: 416 W. 2nd St.
Winnemucca, NV. 89445

ADDRESS AT WELL LOCATION: 3520 Mark Lane
Winnemucca, NV. 89445

2. LOCATION: S/E ¼ S/W ¼ Sec. 10 T. 37 N/S R. 38 E Humboldt County
PERMIT NO. "NA" (Issued by Water Resources) 06-481-25 (Parcel No.) Delaney Subdivision (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 3 | 3 |
| Lava Rock w/s Clay | | 3 | 60 | 57 |
| Gravel and Clay | | 60 | 100 | 40 |
| Gravel w/s clay | | 100 | 125 | 25 |

'88 OCT 25 A10:09
STATE ENGINEERS OFFICE

Date started: October 10, 19 88
Date completed: October 11, 19 88

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 30 | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 125 feet
Casing record 125 ft.
Weight per foot ..... Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 inches | +1 feet | 125 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type Concrete
Depth of seal 50 ft. feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 125 feet

Perforations:
Type perforation Millslot
Size perforation 1/8 in.
From 104 feet to 125 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow None G.P.M. ..... P.S.I.
Water temperature Cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Brinkerhoff (Contractor)
Address P.O. Box 1878 Winnemucca, NV. 89445 (Contractor)
Nevada contractor's license number 0020578
Nevada contractor's drillers number 1161
Nevada driller's license number 730 (Actual Driller)
Signed Gerald Lee Mary (Contractor)
Date October 21, 1988

(Rev. 6-81)

USE ADDITIONAL SHEETS IF NECESSARY

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. ~~32267~~ 30575
Permit No.
Basin 4-69

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7303

1. OWNER Jim Delaney
MAILING ADDRESS 416 W. 2nd St.
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
Winnemucca, NV 89445

2. LOCATION S/E ¼ S/W ¼ Sec. 10 T. 37 N/S R. 38 E Humboldt County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 3 | 3 |
| Lava Rock w/s Clay | | 3 | 60 | 57 |
| Gravel and Clay | | 60 | 100 | 40 |
| Gravel w/s clay | | 100 | 125 | 25 |

Date started October 10, 19 88
Date completed October 11, 19 88

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 30 | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 125 feet
Casing record 125 ft.
Weight per foot ..... Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 inches | +1 feet | 125 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type Concrete
Depth of seal 50 ft. feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 125 feet

Perforations:
Type perforation Millslot
Size perforation 1/8 in.
From 104 feet to 125 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Brinkerhoff
Contractor
Address P.O. Box 1878 Winnemucca, NV 89445
Contractor
Nevada contractor's license number 0020578
Nevada contractor's drillers number 1161
Nevada driller's license number 730
Actual Driller
Signed Gerald Lee Mory
Contractor
Date October 21, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434