

OFFICE USE ONLY
 Log No. 30586
 Permit No. 53184
 Basin 11-1896

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY **TW15** Please complete this form in its entirety

NOTICE OF INTENT NO. 10651

1. OWNER Sierra Pac Resources ADDRESS AT WELL LOCATION
 MAILING ADDRESS PO Box 30150
Reno Nev 89520 Winecup Ranch
Wells NV
 2. LOCATION NW 1/4 SW 1/4 Sec 9 T. 39 N/S R. 66 E Elko County
 PERMIT NO. 257 Issued by Water Resources Parcel No. Winecup Ranch Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay lt tan soft		0	10	
Gravel or gravel coarse		10	20	
Gravel & clay		20	40	
Clay lt tan silty		40	50	
Clay lt tan - some blk gravel		50	85	
Siltstone lt tan some blk gravel		85	110	
Clay lt tan - gravel		110	130	
Clay lt tan silty		130	150	
Clay n n		150	225	
Gravel blk tan pea size		225	275	
Sandstone lt tan		275	310	
Gravel fine pea size		310	340	
Sandstone lt tan well sorted		340	350	
Gravel blk blk - clean round		350	400	
Shale lt olive green		400	425	
Trace blk volcanic glass				

8. WELL CONSTRUCTION
 Diameter 9 3/8 inches Total depth 425 feet
 Casing record
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>6</u> inches	<u>1</u> feet	<u>395</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 60' feet
 Gravel packed: Yes No
 Gravel packed from 245 feet to 415 feet
 Perforations:
 Type perforation factory
 Size perforation 0.02
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 8-17 1988
 Date completed 8-25 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 211.95 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name R.D. Reynolds Contractor
 Address PO Box 402 Wells NV Contractor
 Nevada contractor's license number 014410 issued by the State Contractor's Board
 Nevada contractor's driller's number 1390 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1390
 Signed R.D. Reynolds By driller performing actual drilling on site or contractor
 Date 10-11-88