

OFFICE USE ONLY
 Log No. 30630
 Permit No. _____
 Basin 9-108

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9675

1. OWNER WILMARTH DENSMORE ADDRESS AT WELL LOCATION SAME AS
 MAILING ADDRESS 210 DENSMORE LN. MAZELZWE
VERMONT, NV. 89447
 2. LOCATION N.R. 1/4 SW 1/4 Sec 1 T. 14 S R. 25 E LYON County
 PERMIT NO. 14-531-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------|--------------|------|----|------------|
| Brown Clay | | 0 | 3 | 3 |
| COURSE SAND | | 3 | 10 | 7 |
| COURSE SAND & GRAVEL | | 10 | 30 | 20 |
| C. SAND & Blue Clay | | 30 | 35 | 5 |
| C. SAND | | 35 | 37 | 2 |
| Brown Clay | | 37 | 38 | 1 |
| C. SAND | | 38 | 58 | 20 |
| Brown Clay | | 58 | 60 | 2 |
| C. SAND & GRAVEL | | 60 | 80 | 20 |
| GRAVEL & C. SAND | X | 80 | 90 | 10 |
| Brown Clay & GRAVEL | | 90 | 92 | 2 |
| GRAVEL & C. SAND | X | 92 | 98 | 6 |

8. WELL CONSTRUCTION
 Diameter 10 5/8 inches Total depth 99 feet
 _____ inches
 _____ inches
 Casing record _____
 Weight per foot _____ Thickness 156
 Diameter From To
6 3/8 inches 1 feet 98 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type GRAVEL
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 98 feet
 Perforations:
 Type perforation SAWED
 Size perforation 3/32" x 3" x 6 Rows
 From 78 feet to 98 feet
 From _____ feet to _____ feet

Date started 11-5, 1988
 Date completed 11-10, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------|-----------|-----------|------------------|
| <u>3600</u> | <u>60</u> | <u>8</u> | <u>8</u> |
| | | | |
| | | | |

BAILER TEST
 G.P.M. 20 Draw down 2 feet 1/2 hour
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 12 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name OGDEN BROS. DRILLING Contractor
VERMONT
 Address 162 N. BYBEE LN. NV 89447 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada contractor's driller's number issued by the Division of Water Resources 8704630
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 270
 Signed Billy Cole
 By driller performing actual drilling on site or contractor
 Date 11/13/88