

OFFICE USE ONLY
 Log No. 300418
 Permit No. _____
 Basin 4-45

I

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER Emery Ramsey 7536714 ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Lancille, N.Y. 07828

2. LOCATION Sw 1/4 NE 1/4 Sec 6 T. 33 N/S R. 5E E ELKO County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/>	5. TYPE WELL Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Other <input type="checkbox"/>
--	---	---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy loam</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Caliche</u>		<u>3</u>	<u>4</u>	<u>1</u>
<u>Sandy clay</u>		<u>4</u>	<u>10</u>	<u>6</u>
<u>Sand</u>		<u>10</u>	<u>20</u>	<u>10</u>
<u>Sandy clay</u>		<u>20</u>	<u>118</u>	<u>98</u>
<u>Sand</u>	<input checked="" type="checkbox"/>	<u>118</u>	<u>119</u>	<u>1</u>
<u>Clay within streak of sand</u>	<input checked="" type="checkbox"/>	<u>119</u>	<u>154</u>	<u>3.5</u>
<u>Clay</u>		<u>154</u>	<u>158</u>	
	<u>T.D</u>	<u>158</u>		

8. WELL CONSTRUCTION

Diameter 1.0 inches Total depth 158 feet
7 7/8 inches 50 to 158
 inches
 Casing record 159 ft. steel
 Weight per foot 12.92 Thickness 1.08

Diameter	From	To
<u>6 7/8</u> inches	<u>+1</u> feet	<u>1.58</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement grout
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Taper cut
 Size perforation 1/2" x 4" x 2/8"
 From 1.8 feet to 1.58 feet
 From _____ feet to _____ feet

Date started 9/26 1988
 Date completed 9/30 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 40 Draw down 30 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 62 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING CO. Contractor
 Address 203 PINE ST., ELKO 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada contractor's driller's number issued by the Division of Water Resources 632
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632

Signed Emery Y. Muth
 By driller performing actual drilling on site or contractor
 Date 11/22/88