WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30665
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10881

1. OWNER Miles Bros Construction
MAILING ADDRESS Box 209 Dayton Nevada
ADDRESS AT WELL LOCATION 1926 Jungo Court

2. LOCATION SE ¼ NW ¼ Sec. 12 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-231-09 (Parcel No.) Sagewood Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Cobbles with Clay		3	30	27
Tight Clay With Small Gravels		30	160	130
Hard Cemented Gravels		160	220	60
Gravel with fine sand Carrying Water	✓	220	240	20
T.D. 240 Ft				

RECEIVED DEC 21 '88 A9:34 STATE ENGINEERS OFFICE

Date started Dec 12, 1988
Date completed Dec 14, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean water to remove drill Mud & to Gravel pack Developed with 250 psi air for 3 hours making 20 GPM from 210 FT			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11½ inches Total depth 240 feet
Casing record 6 5/8" Steel
Weight per foot ..... Thickness .188

Diameter		From		To	
6	inches	+2	feet	240	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3/32" x 3"
From 220 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 202 feet below land surface
Flow 20 G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5551 Hwy 50 E Carson City, NV (Contractor)
Nevada contractor's license number 13695
Nevada contractor's drillers number
Nevada driller's license number 1450 (Actual Driller)
Signed Clinton R Butts (Contractor)
Date Dec 16, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434