WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30673
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10855

1. OWNER Paul Conrad
MAILING ADDRESS Box 1201 Zephyr Cove Nev
ADDRESS AT WELL LOCATION 1571 E. Valley Rd. Genoa Nev
2. LOCATION NE ¼ NW ¼ Sec. 35 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-290-72 (Parcel No.) None (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Clay with Gravel		2	40	38
Sand with Clay Stringers		40	120	80
Clay with Gravel		120	145	25
Gravel & with Water		145	170	25

STATE ENGINEERS OFFICE RECEIVED DEC 21 A9:34 '88

Date started Nov 30, 1988
Date completed Dec 2, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with air Hole making 25 to 30 G.P.M.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 170' feet
..... inches
..... inches
Casing record 6 5/8 Steel
Weight per foot 18.97 Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 53' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 52' feet to 170' feet

Perforations:
Type perforation Mill slot
Size perforation 32/32 x 3
From 150 feet to 170' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow 25+ G.P.M. ~~[illegible]~~ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+A Pump Co. (Contractor)
Address 5551 Hwy 50 East Carson City (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Clarence Butts (By driller performing actual drilling on site or contractor)
Date Dec 2, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627