

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9196

1. OWNER Clear Creek Enterprises/Ed Roberts ADDRESS AT WELL LOCATION
 MAILING ADDRESS P. O. Box 1882 Warehouse Way & Industrial Way
Carson City, Nv 89702

2. LOCATION NW 1/4 NE 1/4 Sec 6 T 14 N/S R. 20 E Douglas County
 PERMIT NO. 49547 Issued by Water Resources Parcel No. 013-210-05 Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. Commercial PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown tan white D.G.		0	32	32
Green white yellow D.G. compact with fractured zones		32	263	231
Light brown clay with brown yellow & white d.g.		263	288	25
Black & white granite hard fractured		288	308	20
T.D. 308				

8. 12 1/2"-55' WELL CONSTRUCTION
 Diameter 10 5/8 inches Total depth 308 feet
7 7/8 inches
 inches
 Casing record 8 5/8
 Weight per foot 19.96 & 10.78 Thickness .183 & .156

Diameter	From	To
<u>8 5/8</u> inches	<u>+1 1/2</u> feet	<u>258</u> feet
<u>6 5/8</u> inches	<u>246</u> feet	<u>308</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 258 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 196 feet to 233 feet
 From 288 double feet to 308 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9/30/88, 19____
 Date completed 10/6/88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>150</u>	<u>141' 5"</u>	<u>12 hours</u>

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 42 feet below land surface
 Flow 100+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv
 Contractor 89431
 Nevada contractor's license number issued by the State Contractor's Board [1132] 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10/10/88