

**ATB**

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12209

1. OWNER Robert Journey ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3350 Pershing LN 3340 Pershing LN  
Washoe City NV. 89704 WASHOE CITY NV 89704  
 2. LOCATION SE 1/4 NE 1/4 Sec. 6 T. 16 N/S R. 20 E Washoe County  
 PERMIT NO. 050-444-17 Washoe Valley Farms  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP soil & cobbles		0	5	5
BROWN CLAY & cobbles		5	10	5
Brown CLAY, sand, gravel		10	50	40
Grey CLAY & MULTI-COLORED ROCK		50	60	10
Sand & gravel, some CLAY		60	70	10
Brown sandy CLAY & sand		70	90	20
Brown CLAY		90	93	3
Sand & CLAY		93	100	7
Sand & CLAY		100	107	7
Brown CLAY		107	112	5

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 112 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 65/8"  
 Weight per foot 12.89 Thickness .188  

Diameter	From	To
<u>65/8</u> inches	0 feet	112 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 112 feet

Perforations:  
 Type perforation FACTORY Double Standard  
 Size perforation 3/32 x 3  
 From 72 feet to 112 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-8, 1988  
 Date completed 12-9, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
			DEC 15 10:40

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 7' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 64 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sam Woods Energy Exploration  
Contractor  
 Address PO Box 1538 Minden NV 89423  
Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21491  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407  
 Signed Sam Woods  
By driller performing actual drilling on site or contractor  
 Date 12-9-88