

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11995

PRINT OR TYPE ONLY

1. OWNER Maude Hammond ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1887 E. Belle Fallon, NV. 89406 Same as at mailing
 2. LOCATION NE 1/4 NW 1/4 Sec. 19 T. 19 N. R. 28 E. Churchill County _____
 PERMIT NO. None Issued by Water Resources Parcel No. None Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERburden		0	10	10
Brown sand (water present)		10	15	5
Brown sand				
Clay mixed		15	25	10
Brown Clay		25	39	9
light gray sand				
coarse sand fine				
(little water)				
Brown sand				
Clay mixed		39	48	9
light gray sand				
Coarse sand fine (little water)	X	48	50	2
Brown Clay		50	51.8"	1.8"
Brown gravel				
Coarse sand mixed	X	51.8"	56"	4.4"

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 56 feet
 _____ inches
 _____ inches
 Casing record 2 1/2 + 56'
 Weight per foot 17.02 Thickness .250

Diameter	From	To
<u>6</u> inches	<u>+2 1/2"</u>	<u>56'</u>
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type neat
 Depth of seal 50ft. feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 56 feet
 Perforations:
 Type perforation Torch Cut
 Size perforation 3/32 x 4"
 From 53 feet to 56 feet
 From _____ feet to _____ feet

Date started 12-12- 1988
 Date completed 12-17 1988

DEC 29 AM 10:01
 REGISTERED ENGINEERS OF NV
 STATE ENGINEERS OFFICE

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>18</u>	<u>8</u>	<u>2</u>
<u>(Don't Exceed 15 gpm.)</u>			
<u>Set pump at</u>		<u>40</u>	

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 12' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Excellent

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water-Rite Well Drilling
 Address 3100 Patton Rd, Fallon, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 0023978
 Nevada contractor's driller's number issued by the Division of Water Resources 1525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1525
 Signed Sam Ukum
 By driller performing actual drilling on site or contractor
 Date 12-19-88