WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30707
Permit No. 51477
Basin 6.85 Spanish Springs V

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9800

1. OWNER Golden West / Sunset Assoc.
MAILING ADDRESS 255 Glendale Ave. Suite 15
Sparks Nev 89431

ADDRESS AT WELL LOCATION
Pyramid Lake Highway
Parcel 1 of map # 1747

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 21 N/S R. 20 E. Washoe County

PERMIT NO. 51477 (Issued by Water Resources) | 76-635-11 (Parcel No.) | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay stringers with Brown yellow Reddish brown green and white volcanic sands (Clay 2-3' sections)		0	235	235
Volcanic Sands			235	256
Green clay with Traces of volcanic sand.			256	305
Green clay			305	330

'88 DEC -8 A10:07
RECEIVED
STATE ENGINEERS OFFICE

Date started 10 11, 1988
Date completed 11 14, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	250		12
	86	10	72

BAILER TEST

G.P.M. None Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 22 inches Total depth 330 feet
..... inches
..... inches
Casing record 14"
Weight per foot ..... Thickness .250

Diameter	From	To
14 inches	+1 feet	330 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 330 feet

Perforations:
Type perforation .100 slot well screen
Size perforation
From 150 feet to 320 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 20 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Oasis Drilling Inc.
Contractor

Address P.O. Box 21421 Carson City Nev 89721
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0023129

Nevada contractor's driller's number issued by the Division of Water Resources .....

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386

Signed T. L. Amzo
By driller performing actual drilling on site or contractor

Date Dec. 6 - 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627