WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30709
Permit No.
Basin 6-84

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9190

1. OWNER Ronald Shapiro
MAILING ADDRESS 1501 Hopi Trail
Santa Rosa, Ca 95404

ADDRESS AT WELL LOCATION
4705 Axe Handle Canyon Rd
~~Parcel 3 of~~ Parcel # 32-2-1-3

2. LOCATION NE ¼ NW ¼ Sec. 32 T 22 N/S R. 21 E Washoe County
PERMIT NO. — (Issued by Water Resources) 076-180-21 (Parcel No.) Palomino Valley Unit 4 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary XX
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay & sand		0	4	4
Green & white compact D/G.				
Brown yellow white D.G. firm & fractured		15	87	72
Dark green yellow white & black D.G.		87	554	467
Light green & white fractured granite	563	554	578	24
T.D. 578				
P&A by log # 49991				

STATE ENGINEERS OFFICE
RECEIVED
DEC 22 A9:24 '88

Date started 9/26/88, 19
Date completed 9/28/88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8½ inches Total depth 578 feet
inches
inches
Casing record 6 5/8"
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	578 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX No ☐ Type grout
Depth of seal 53 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 53 feet to 578 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 558 feet to 578 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 185 feet below land surface
Flow 20+ G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, INc. (Contractor)
Address 625 Spice Islands Dr. Suite 1 Sparks, Nv 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 10/3/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627