

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7996

1. OWNER DUANE HOLUM ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 8575 Vicky Lane  
Sabastopol, CA 95472  
 2. LOCATION NW 1/4 NE 1/4 Sec 25 T 33 R 55 E Elko County  
 PERMIT NO. \_\_\_\_\_ Lot 4 Block E Western Hills Subdivision Name  
Issued by Water Resources Parcel No.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0'	5'	5'
Clay & Med. Sand		5'	50'	45'
Clay & fine Sand		50'	60'	10'
Coarse sand & clay		60'	90'	30'
Fine Sand & <del>clay</del> gravel		95'	110'	15'
Fine sand & clay		110'	155'	45'
Coarse sand & fine gr.		155'	160'	5'
Rocks & Coarse gravel		160'	180'	20'
First water at 70 feet.				

8. WELL CONSTRUCTION

Diameter 50'-10 inches Total depth 180 feet  
130-8 inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot 2.95 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 180 feet

Perforations:  
 Type perforation machine slots  
 Size perforation 1/8"  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-9, 1988  
 Date completed 12-12, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blow Test</u>	<u>20 gpm</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 45 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor  
 Address P.O. Box 850 Elko, NV 89801 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada contractor's driller's number issued by the Division of Water Resources 1166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1395  
 Signed Dale C. Vedon  
 By driller performing actual drilling on site or contractor  
 Date 12-12-88