WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30734
Permit No. 51389
Basin 166- KELLEY CREEK AREA

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9702

1. OWNER PINSON MINING COMPANY
MAILING ADDRESS P. O. BOX 192
WINNEMUCCA, NEVADA 89445

ADDRESS AT WELL LOCATION PINSON MINE Well #10

2. LOCATION SW ¼ SW ¼ Sec. 28 T. 38 N/S R. 42 E. HUMBOLDT County
PERMIT NO. W-243 /51390 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE PW# 10
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & clay		0	35	35
broken rock & clay				
shale		35	325	190
solid rock		325	340	15
black shale rock		340	410	70
medium dense black				
rock		410	580	170
very dense black rock				
hard		580	730	150
Replacement of well				
Log # 29267				
Electric geophysical well log				
by: GEO-HYDRO DATA				

'88 DEC 12 A11:02 RECEIVED STATE ENGINEERS OFFICE

Date started DECEMBER 3, 1987
Date completed DECEMBER 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	20		8

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 542 feet
..... inches
..... inches
Casing record 8-5/8" O.D. x .250" wall
Weight per foot 22.36 Thickness .....

Diameter	From	To
8 inches	+1 feet	542 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement sand grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 542 feet
Wadsworth 7/16" minus well rock
Perforations:
Type perforation Milled
Size perforation 3" x 3/32" dbl std spacing
From 242 feet to 542 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 280 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 66 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 N. VIRGINIA ST. RENO, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1491
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JANUARY 20, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627