WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30735
Permit No. 52464
Basin 04-066 Kelley Creek Area

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10169

1. OWNER PINSON MINING COMPANY
MAILING ADDRESS P. O. BOX 192
WINNEMUCCA, NEVADA 89445

ADDRESS AT WELL LOCATION
PINSON MINE - NORTHEAST GOLCONDA

2. LOCATION NW ¼ SW ¼ Sec. 29 T 38 N/S R 42 E HUMBOLDT County
PERMIT NO. W-288 / 52464 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE PW# 11
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
small to large sand & silt		0	47	47
bed rock (very soft) black shale & sand		47	130	83
black shale & limestone		130	175	45
black shale		175	180	5
black shale w/small limestone chips		180	220	40
black shale		220	510	190

DEC 12 '88 A11:02
RECEIVED STATE ENGINEERS OFFICE

Date started October 7, 1988
Date completed October 25, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	150 to 200		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 505 feet
..... inches
..... inches
Casing record 8-5/8" O.D. x 1/4" wall
Weight per foot 22.36 Thickness .....

Diameter	From	To
8 inches	+1 feet	505 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type cement sand grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 505 feet
Wadsworth 3/8" minus well rock
Perforations:
Type perforation MILLED
Size perforation 2-1/2" x 3/32" slot dbl std space
From 105 feet to 505 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 83 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 N. VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed [signature] (By driller performing actual drilling on site or contractor)
Date NOVEMBER 2, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627