WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 87-41
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3169

1. OWNER Larry Michler
MAILING ADDRESS Sierra Way Lot 25
Fallon, Nv. 89406

ADDRESS AT WELL LOCATION Same as Owner

2. LOCATION SW ¼ NE ¼ Sec. 25 T 18 N/S R. 28 E Churchille County
PERMIT NO. None (Issued by Water Resources) | None (Parcel No.) | None (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	8	8'
Brown Sand				
Course		8	15	7'
Brown Clay		15	23	8'
Broken Volcanics				
(Black)		23	32	9'
Fine Brown				
sand		32	51	19'
Fine Brown sand				
Clay mixed		51	56	5'
Light gray sand				
Clay mixed		56	69	13'
Brown sand				
Course	X	69	75	6'
Brown sand				
Course gravel				
mixed	X	75	80	5'

FEB 2 A9:59 '89 STATE ENGINEER'S OFFICE

Date started 1-27, 19 89
Date completed 1-30, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	18	15'	2 hours

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 80'-2" feet
..... inches
..... inches
Casing record 81'-8"
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+18" feet	80'-2" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 50 Ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 80'-2" feet to 78'-2" feet

Perforations:
Type perforation Torch Cut
Size perforation 5/32
From 80'-2" feet to 78'-2" feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 17 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address 3400 Bottom Rd. #1 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1525
Signed Sam Olson (By driller performing actual drilling on site or contractor)
Date 2-1-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627