

OFFICE USE ONLY
Log No. 30778
Permit No. _____
Basin 8-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11864

PRINT OR TYPE ONLY

1. OWNER Hickey Const. ADDRESS AT WELL LOCATION _____
MAILING ADDRESS PO Box 14203 1419 Stephanie Ln
Miners Nu. 89423
2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec 34 T 14 N/S/R. 20 E Douglas County
PERMIT NO. _____ Parcel No. _____ Subdivision Name Jehua Inc
Issued by Water Resources

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Other

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------|--------------|------------|------------|------------|
| <u>Clay & Sand</u> | | <u>0</u> | <u>20</u> | |
| <u>Sand</u> | | <u>20</u> | <u>35</u> | |
| <u>Clay & Sand</u> | <u>X</u> | <u>35</u> | <u>65</u> | |
| <u>Clay Sand & gravel</u> | <u>X</u> | <u>65</u> | <u>80</u> | |
| <u>Clay & gravel</u> | <u>X</u> | <u>80</u> | <u>100</u> | |
| <u>Clay</u> | <u>X</u> | <u>100</u> | <u>110</u> | |
| <u>Clay Sand & gravel</u> | <u>XX</u> | <u>110</u> | <u>140</u> | |

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 140 feet
_____ inches
_____ inches

Casing record _____
Weight per foot _____ Thickness 11.87

| Diameter | From | To |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>0</u> feet | <u>140</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type _____
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation Factory Roof
Size perforation 1/16 x 3"
From 120 feet to 140 feet
From _____ feet to _____ feet

Date started 12-18, 1988
Date completed 12-20, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level 40 feet below land surface
Flow 201 G.P.M. _____ P.S.I.
Water temperature 64 °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Rouchack Drilling Inc. Contractor
Address 1578 Chiquita Miners Nu Contractor
Nevada contractor's license number issued by the State Contractor's Board #024268
Nevada contractor's driller's number issued by the Division of Water Resources #1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen
By driller performing actual drilling on site or contractor
Date 12-23-88

BAILER TEST

G.P.M. 80+ Draw down 5 feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours