WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30780
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12435

1. OWNER C. Ray Pierson
MAILING ADDRESS 4420 East Lake Blvd
Carson City, Nevada 89706
ADDRESS AT WELL LOCATION 4420 East Lake Blvd.
Carson City, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 5 T. 16 N/S R. 20 E/W Douglas County
PERMIT NO. ~~UT-4023~~ (Issued by Water Resources) Parcel No. Subdivision Name: New Washoe City, etc

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cement Gravel		0	110	110
Hard fine grain sandstone w/ fractures carrying water	✓	110	140	30'
TD 140'				

RECEIVED JAN 18 '89 A9:54 STATE ENGINEER'S OFFICE

Date started 1/8, 1989
Date completed 1/9, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed, Cleaned & Gravel packed with 1250 psi air			
Bled 4 hours from 130'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4" inches Total depth 140' feet
..... inches
..... inches
Casing record 42-140'
Weight per foot 117 Thickness .156

Diameter	From	To
6 5/8 inches	27 feet	120' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 50'
Gravel packed: Yes ☑ No ☐
Gravel packed from 50' feet to 140' feet

Perforations:
Type perforation Mill Slot
Size perforation 3/32 X 3 1/2
From 120' feet to 140' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 83 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HH Pump Co. (Contractor)
Address 5551 Hy 50 East Carson City NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 33295
Nevada contractor's driller's number issued by the Division of Water Resources 1472
Nevada driller's license number issued by the Division of Water Resources, the on-site driller .....
Signed Quentin R. Pratt (By driller performing actual drilling on site or contractor)
Date 1/9/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627