WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

30781 OFFICE USE ONLY
Log No. 30781
Permit No.
Basin 6-89

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10884

1. OWNER Bailey Const. Co.
MAILING ADDRESS 2116 Thomas Jefferson Reno, Nevada 89508
ADDRESS AT WELL LOCATION East Washoe 430 Flicker Carson City, Nv 89701

2. LOCATION NE ¼ NW ¼ Sec. 5 T. 16 N/S R. 70 E. Washoe County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources | 050-414-01. Parcel No. | New Washoe City #5 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Loose gravels, Sand with Clay Seams		2	132	130
Clean gravel w/ Sand Carrying water	–	132	160	28
Deepened under NOI 612.14				
N39.285655 W119.761966 NAD27				
T.D. 160'				

'89 JAN 18 A9:54
RECEIVED STATE ENGINEERS OFFICE

Date started Jan 11, 1989
Date completed Jan 13, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove mud & gravel pack			
Developed 2 hrs with air 120+ GPM from 140'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11 1/4 inches Total depth 160 feet
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 53 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to 160 feet

Perforations:
Type perforation Factory Mill
Size perforation 3/32" x 3"
From 140 feet to 160 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 82 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address 5551 Hiway 50 E #3 C City Nv
Contractor
Nevada contractor's license number 23095
Nevada contractor's drillers number .....
Nevada driller's license number 1450
Actual Driller
Signed Clinton R Butts
Contractor
Date January 14, 1989

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434