WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30784
Permit No. 50540
Basin 6-88

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10878

1. OWNER OLD GALENA LTD
MAILING ADDRESS 4790 SLIDEMTN
RENO, NEVADA 89510

ADDRESS AT WELL LOCATION Callahan Rd Area
4790 SLIDE MOUNTAIN
RENO, NEVADA 89510

2. LOCATION SW ¼ SE ¼ Sec. 2 T. 17 N/S R. 19 E. WASHOE County
PERMIT NO. 50540 (Issued by Water Resources) | Parcel No. | OLD GALENA TOWNSITE (Subdivision Name)

W Cty #

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐
FIRE PROTECTION

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	2	2
COBBLES WITH SAND & SMALL ROCK		2	87	85
GRAVELS WITH WATER	–	87	118	33
HARD GRANITE		118	120	2
T.D. 120 FT				

'89 JAN 10 A10:12
RECEIVED
STATE ENGINEERS OFFICE

Date started December 20, 1988
Date completed December 21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed & gravel packed with air for 2 hours Well making 30+ GPM from 100 Ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11 1/2 inches Total depth 120 feet
Casing record 6 5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 53 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to ..... feet

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3/32" X 3"
From 100 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 30+ G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 5551 Hiway 50 E C City, Nv (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number .....
Nevada driller's license number 1450 (Actual Driller)
Signed Quinton R Butts (Contractor)
Date December 22, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434