

OFFICE USE ONLY  
 Log No. 30786  
 Permit No. \_\_\_\_\_  
 Basin 6-89

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 9217

PRINT OR TYPE ONLY

1. OWNER JOE GIEBEL ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 1385 Dunbar  
Carson City, NV 89701  
 2. LOCATION SW 1/4 NW 1/4 Sec. 30 T. 17N N/S R. 20 E Washoe County  
 PERMIT NO. \_\_\_\_\_ N. Washoe Valley #1 E, S & E, I Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

|  |  |  |
|--|--|--|
| 3. TYPE OF WORK                            | 4. PROPOSED USE                              | 5. TYPE WELL                               |
| New Well <input type="checkbox"/>          | Domestic <input checked="" type="checkbox"/> | Cable <input type="checkbox"/>             |
| Recondition <input type="checkbox"/>       | Irrigation <input type="checkbox"/>          | Rotary <input checked="" type="checkbox"/> |
| Deepen <input checked="" type="checkbox"/> | Industrial <input type="checkbox"/>          | Other <input type="checkbox"/>             |
| Other <input type="checkbox"/>             | Stock <input type="checkbox"/>               | air <input type="checkbox"/>               |
| Municipal <input type="checkbox"/>         |  |  |

6. LITHOLOGIC LOG

| Material                               | Water Strata | From | To  | Thick-ness |
|--|--------------|------|-----|------------|
| WELL DEEPENING:                        |              |      |     |            |
| Gravel, wood & garden hose             |              | 65   | 81  | 6          |
| Weathered granite                      |              | 81   | 95  | 14         |
| Soft zone (app. 2 GPM)                 | X            | 95   | 99  | 4          |
| Weathered granite                      |              | 99   | 115 | 16         |
| Soft zone (No water)                   |              | 118  | 121 | 3          |
| Weathered granite                      |              | 121  | 135 | 14         |
| Soft fracture granite w/clay streaks.  | X            | 135  | 147 | 12         |
| Brown clay streaks w/weathered granite |              | 147  | 211 | 64         |
| Red cclay                              |              | 211  | 213 | 2          |
| Brown clay streaks w/weathered granite |              | 213  | 250 | 37         |
| From 150 to 250 back fill.             |              |      |     |            |

8. WELL CONSTRUCTION

Diameter 5 inches Total depth 150 feet

Casing record 150' steel casing installed.

Weight per foot \_\_\_\_\_ Thickness .134

| Diameter     | From       | To         |
|--------------|------------|------------|
| 5" OD inches | 0 feet     | 150 feet   |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes  No  Type N/A

Depth of seal \_\_\_\_\_ feet

Gravel packed: Yes  No

Gravel packed from 60 feet to 150 feet

Perforations:

Type perforation factory sawed slot

Size perforation 3/32 x 3 x 5 around

From 85 feet to 145 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-3-89, 19\_\_\_\_  
 Date completed 1-4-89, 19\_\_\_\_

7. WELL TEST DATA

| Pump RPM  | G.P.M.         | Draw Down | After Hours Pump |
|-----------|----------------|-----------|------------------|
| <u>68</u> | <u>STATION</u> |           |                  |
|           |                |           |                  |
|           |                |           |                  |

9. WATER LEVEL

Static water level 51 feet below land surface

Flow 6 G.P.M. \_\_\_\_\_ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor

Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number 22549 issued by the State Contractor's Board.

Nevada contractor's driller's number 908 issued by the Division of Water Resources.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 923

Signed [Signature] By driller performing actual drilling on site or contractor

Date January 5, 1989

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours