WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30796
Permit No.
Basin 101-CARSON DESERT

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12240

1. OWNER BOB ADAMS
MAILING ADDRESS 3000 STARK LANE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 3000 STARK LANE
FALLON, NV 89406

2. LOCATION NW ¼ SW ¼ Sec. 34 T 19 N/S R 29 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
SAND		6	9	3
SAND &CLAY	X	9	17	8
SAND	X	17	30	13
CLAY		30	32	2
GRAY SAND & SILT		32	65	33
CLAY		65	67	2
BLACK SAND & SILT	X	67	83	16
CLAY		83	87	4
SAND & CLAY LAYERS		87	95	8
CLAY		95	97	2
SAND & GRAVEL		97	111	14
CLAY		111		

'89 JAN 31 A9:41
STATE ENGINEER'S OFFICE

Date started JANUARY 29, 1989
Date completed JANUARY 29, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	@ 25 GPM		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 111 feet
inches
inches
Casing record 6 5/8 X 111'
Weight per foot 12.9 Thickness .188

Diameter	From	To
6 inches	0 feet	111 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32 X 3
From 103 feet to 109 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 7 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 60 °F Quality UNKWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JANUARY 30, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627