

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. Monitor

1. OWNER City of Winnemucca ADDRESS AT WELL LOCATION Monitor #3  
 MAILING ADDRESS Humboldt County Courthouse Jungo Rd Sewer Plant  
Winnemucca, NV 89445  
 2. LOCATION SE 1/4 SW 1/4 Sec 25 T. 36 N/S R. 37 E Humboldt County  
 PERMIT NO. Monitor Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	7	7
Silt		7	15	
<i>Not waived. see M/O-1968</i>				
<i>M/O-271</i>				
<i>STATE ENGINEERS OFFICIAL</i>				
<i>JAN -9 AM 10:26</i>				
<i>'89</i>				

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 15 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 4" PVC  
 Weight per foot \_\_\_\_\_ Thickness SCH 40  
 Diameter From To  
 4" BLANK inches 0 feet 5 feet  
 4" PERF inches 5 feet 10 feet  
 4" BLANK inches 10 feet 15 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 3 feet  
 Gravel packed: Yes  No  Sand pack 4 - 15ft  
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Bentonite Seal 3 - 4ft

Perforations:  
 Type perforation PVC Sch 40 Slot  
 Size perforation .002  
 From 5 feet to 10 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12/20 1988  
 Date completed 12/20 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 11' 2" feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co. Inc  
 Address P. O. Box 592 Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada contractor's driller's number issued by the Division of Water Resources C-23  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448  
 Signed \_\_\_\_\_  
 Date 12-23-88