

RECEIVED JAN 0 3 1989

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 30830  
Permit No. \_\_\_\_\_  
Basin LI-42

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11875

1. OWNER Chevron USA Inc. ADDRESS AT WELL LOCATION Chevron Station  
 MAILING ADDRESS 2410 Camine Ramon I 80 and U.S. 93  
San Ramon, CA 94583 Wells, Nevada  
 2. LOCATION NE 1/4 SW 1/4 Sec. 10 T 37 N S R. 62 E Elko County  
 PERMIT NO. 50019-X Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  hollow stem

6. CHW-1 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>clayey silty sand</u>		<u>0</u>	<u>2 1/2</u>	
<u>light brown clayey silt</u>		<u>4 1/2</u>	<u>6</u>	
<u>clayey silt</u>		<u>9 1/2</u>	<u>10</u>	
<u>sandy medium gravel</u>		<u>10</u>	<u>11</u>	
<u>fractured silty clay</u>		<u>14 1/2</u>	<u>20</u>	

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 20 feet  
 Casing record PVC  
 Weight per foot \_\_\_\_\_ Thickness Sch 40  

Diameter	From	To
<u>4</u> inches	<u>0</u> feet	<u>5</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement-bentonite  
 Depth of seal 0-4 feet  
 Gravel packed: Yes  No   
 Gravel packed from 4 feet to 20 feet

Perforations:  
 Type perforation manufactured slots  
 Size perforation 0.020"  
 From 5 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 10.07 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11-30- 1988  
 Date completed 11-30- 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name John Anderson  
 Address 11635 Belford Rd Reno Nev, 89509  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1028  
 Signed John Anderson  
 Date 1/2/89

RECEIVED  
STATE ENGINEERS OFFICE  
JAN 18 09:46 '89