WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 30847
Permit No.
Basin

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 11000

1. OWNER Sierra Pacific by Woodward Clyde Consult. ADDRESS AT WELL LOCATION Winecup Ranch
MAILING ADDRESS 500 10th St Suite 100 Oakland Ca.

2. LOCATION SW ¼ NW ¼ Sec 5 T 39 N/S R 66 E Elko County
PERMIT NO. W-280 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & tan clay	NO	0	74	74
Brown clay & gravel	"	74	154	84
Gravel	"	154	158	4
Brown Sandy clay & gravel	yes 194	158	218	60
Brown sandy clay	"	218	228	10
Brown sandy clay & gravel in thin layers less than 1 foot	yes	228	240	12
Brown sandy clay	NO	240	253	13
Gravel	yes	253	255	2
Brown clay & gravel in layers of less than 1 foot	yes	255	280	25
Gravel	yes	280	282	2
Brown sandy clay	NO	282	286	4
Brown sandy clay & gravel in very thin layers	yes	286	308	22
Gravel & brown sandy clay	yes	308	318	10
Brown sandy clay	NO	318	331	13
Gravel	yes	331	335	4
Brown sandy clay	NO	335	345	10
Brown clay, very thin layers of gravel	NO	345	358	13
Gravel	yes	358	360	2
Brown clay, sticky very little gravel	NO	360	410	50

Date started 27 Oct, 1988
Date completed 18 Dec, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 28" 0-50 inches Total depth 410 feet
22" 50-410 inches
..... inches
Casing record + 1 - 50 22"
Weight per foot 12" .250 Thickness .375

Diameter	From	To
12 3/4 inches	+ 3 feet	410 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 410 feet to 160 feet

Perforations:
Type perforation Stainless Steel Screen
Size perforation .050
From 200 feet to 260 feet
From 290 feet to 360 feet
From 380 feet to 390 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 194 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 59 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RD Reynolds
Address PO Box 402 Wells Nv (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 1390
Nevada contractor's driller's number issued by the Division of Water Resources 014410
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 517
Signed Blaine Bailey (By driller performing actual drilling on site or contractor)
Date 2 Jan 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627