WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 308167
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5565

1. OWNER DAN PASKE
MAILING ADDRESS BOX 1181
MERCURY, NEV. 89023

ADDRESS AT WELL LOCATION
NOPAH VISTA – PAHRUMP

2. LOCATION N.E. ¼ N.E. ¼ Sec. 16 T. 19 N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) | LOT 3 BLK 2 (Parcel No.) | COUNTRY PLACE II (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY TOP SOIL		0	2	2
SANDY BROWN CLAY		2	5	3
SANDY BROWN CLAY		5	9	4
W/GRAVEL + ROCKS				
SANDY GREY CLAY		9	20	11
SANDY BROWN CLAY		20	28	8
W/GRAVEL + ROCKS				
HARD BROWN CLAY		28	42	14
BROWN CLAY		42	46	4
HARD BROWN CLAY		46	54	8
GREY CLAY		54	62	8
BROWN CLAY		62	93	11
HARD BROWN CLAY		93	96	3
GREY CLAY		96	104	8
BENTONITE CLAY		104	109	5
SANDY GREY CLAY		109	136	27
BROWN CLAY		136	179	43
SANDY BROWN CLAY		179	200	21
W/LAYERS OF GRAVEL				

RECEIVED
OCT 20 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-26, 1988
Date completed 9-30, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 200 feet
inches
inches
Casing record 200 FT. 8 5/8" O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 120 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 105 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING (Contractor)
Address BOX 157 PAHRUMP, NEV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7479-A
Nevada contractor's driller's number issued by the Division of Water Resources 1424
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1427 - STAN HARDIN
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-3-88 10-3-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627