



WELL DRILLER'S REPORT
 Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4645

1. OWNER Ken P. Skaggs ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec. 28 T. 19S N/S R. 53 E Nye County
 PERMIT NO. _____ Parcel No. Bk 2 Lot 2 Subdivision Name Bumarch Estates
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|-----|------------|
| Sand | | 0 | 20 | 20 |
| Clay | | 20 | 78 | 58 |
| Claychie | X | 78 | 82 | 4 |
| Bryl Clay | | 82 | 100 | 18 |
| Claychie | X | 100 | 105 | 5 |
| Mud Corlor Clay | | 105 | 137 | 32 |
| Claychie | | 137 | 141 | 4 |
| Clay w/ Black | | 141 | | |
| Gravel | X | | 160 | 19 |

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 140 feet
 _____ inches
 _____ inches

Casing record 8 3/8
 Weight per foot 14.56 Thickness 156

| Diameter | From | To |
|--------------|----------------|-----------------|
| _____ inches | <u>-1</u> feet | <u>140</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet

Perforations:
 Type perforation Torch
 Size perforation 1/8 x 12 2 Rows
 From 160 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED
 OCT 4 1988
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 5-3-88, 19____
 Date completed 5-4-88, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 45 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling Contractor
 Address 4425 Stacey Ave Las Vegas Contractor
 Nevada contractor's license number issued by the State Contractor's Board 19219
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1081
 Signed B. B. Behrhart
 By driller performing actual drilling on site or contractor
 Date 5-30-88

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours