



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5521

PRINT OR TYPE ONLY

1. OWNER Boni Brock ADDRESS AT WELL LOCATION Blosser Ranch & Barney  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 NW 1/4 Sec 31 T. 12S N/S R. 53 E. Nye County  
 PERMIT NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name Bell Vista Sub Lot 63 Block 1

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To  | Thick-ness |
|----------|--------------|------|-----|------------|
| Clay     |              | 0    | 8   | 8          |
| Caliche  |              | 8    | 14  | 6          |
| Clay     |              | 14   | 31  | 17         |
| Caliche  |              | 31   | 40  | 9          |
| Clay     |              | 40   | 48  | 8          |
| Caliche  | WB           | 48   | 53  | 5          |
| Clay     |              | 53   | 75  | 22         |
| Caliche  | WB           | 75   | 88  | 13         |
| Clay     |              | 88   | 115 | 27         |
| Caliche  | WB           | 115  | 136 | 21         |
| Clay     |              | 136  | 140 | 4          |

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140 feet  
 Casing record 140 ft. 8 5/8 inch  
 Weight per foot 14.11 Thickness 156  
 Diameter 8 5/8 inches From 0 feet To 140 feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 140 feet  
 Perforations:  
 Type perforation SAW  
 Size perforation 1/8 inch by 3 inch  
 From 120 feet to 140 feet

RECEIVED

AUG 29 1988

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 5-17, 1988  
 Date completed 5-20, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S & H Drilling Contractor  
 Address HCB Box 70206 Reno NV  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1426  
 Signed Steve Hannul  
 By driller performing actual drilling on site or contractor  
 Date 7-20-88