WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30943
Permit No.
Basin

NOTICE OF INTENT NO. 5424

PRINT OR TYPE ONLY

1. OWNER Tracy Ambrose
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SE ¼ Sec. 14 T. 21-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| White Clay | | 4 | 22 | 18 |
| Brown Clay | | 22 | 46 | 26 |
| Caliche | | 46 | 50 | 4 |
| Brown Clay | x | 50 | 98 | 48 |
| Caliche | x | 98 | 116 | 18 |
| Brown Clay | x | 116 | 160 | 44 |

RECEIVED
SEP 14 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started August 8, 1988
Date completed August 9, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 gals. Draw down 4 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 160 feet
inches
inches
Casing record 160 ft. of 8 in casing
Weight per foot 14 lbs. Thickness .156

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 160 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch Cut
Size perforation ½ in width 8 in long
From 100 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg Contractor
Address ST. RT. BOX 36525 Contractor
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg
By driller performing actual drilling on site or contractor
Date Sept. 11, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627