WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30978
Permit No. 64551
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5563

1. OWNER J.A. GRAMMAR
MAILING ADDRESS BOX 1144
COTTONWOOD COVE, NV.

ADDRESS AT WELL LOCATION HAFEN RANCH Rd,
SOUTH OF MANSE, PAHRUMP

2. LOCATION N.W. 1/4 N.W. 1/4 Sec. 10 T. 21 N/S R. 54 E. NYE County
PERMIT NO. 64551 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, ROCK, BOULDERS		0	11	11
SANDY BR. CLAY,		11	30	19
GRAVEL + ROCKS				
GRAVEL + ROCKS		30	68	38
SANDY GREY CLAY		68	91	23
BROWN CLAY		91	102	11
HARD BROWN CALICHE		102	119	17
BENTONITE CLAY		119	130	11
BROWNCLAY + CALICHE		130	171	41
HARD BR. CALICHE		171	204	33
BR. CLAY, GRAVEL, ROCKS		204	221	17
BROWN CLAY		221	232	11
BR. CLAY, GRAVEL, ROCKS		232	240	8
BROWN CLAY		240	254	14
BROWN CLAY w/		254	279	25
LAYERS GRAVEL + ROCKS				
GRAVEL + ROCK		279	289	10
BROWN CLAY		289	300	11

RECEIVED
OCT 20 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-8, 1988
Date completed 9-21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1½ H.P.	31	53'	3

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 300 feet
inches
inches
Casing record 300 FT. 8 5/8" O.D. STEEL
Weight per foot 17.4 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 150 feet to 300 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP + DRILLING (Contractor)
Address BOX 157 PAHRUMP, NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7479-A
Nevada contractor's driller's number issued by the Division of Water Resources 1424
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1427 STAN PARDIN
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-26-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627