

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5770

PRINT OR TYPE ONLY

1. OWNER Ralph Manning ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec. 20 T 21S R 54 E County Clark
 PERMIT NO. _____ Parcel No. Lot 12 Subdivision Name Kellogg Ranch Estates

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	6	6
Clay		6	35	29
Caliche		35	41	6
Clay		41	116	75
Clay & gravel		116	120	4
Caliche	WB	120	132	12
Sand & gravel	WB	132	140	8

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 140 ft 8 5/8 inch
 Weight per foot 14.11 Thickness 15.6
 Diameter From To
8 5/8 inches 0 feet 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet
 Perforations:
 Type perforation SAW
 Size perforation 1/8 inch by 3 inch
 From 120 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED

NOV 04 1988

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 9-6, 1988
 Date completed 9-10, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 60 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SAH Drilling Contractor
 Address HCR Box 70906 Pahrump Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22059
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed _____
 Date 9-20-88
 By driller performing actual drilling on site or contractor

BAILER TEST

G.P.M.	Draw down	feet	hours