WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30992
Permit No. 51555
Basin 229

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5763

OWNER Gexa Gold.
MAILING ADDRESS P.O. Box 10877 Reno NV. 89520.
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 7 T. 12S N/S R. 48 E. Nye County
PERMIT NO. 51555 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Gravel & Clay | | 0 | 154 | 154 |
| Intrusive & Clay | | 154 | 210 | 56 |
| Intrusive | WB | 210 | 220 | 10 |
| Limestone | | 220 | 245 | 25 |
| Fractured Lime | WB | 245 | 260 | 15 |
| Limestone | | 260 | 280 | 20 |
| Fractured Silt Stone | WB | 280 | 285 | 5 |
| Intrusive Clay | | 285 | 380 | 95 |
| Silt Stone | | 380 | 405 | 25 |
| Intrusive | | 405 | 560 | 155 |
| Silt Stone | WB. | 560 | 635 | 75 |
| Intrusive | | 635 | 670 | 35 |
| Silt Stone | | 670 | 700 | 30 |

RECEIVED
OCT 28 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-5, 1988
Date completed 9-18, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 700. feet
____ inches
____ inches
Casing record 700 Ft. 6 5/8 inch
Weight per foot 10.1 Thickness .156.

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 700 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 700. feet

Perforations:
Type perforation SAW.
Size perforation ⅛ inch by 3 inch
From 208 feet to 313 feet
From 513 feet to 618 feet
From 658 feet to 700. feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 135 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H Drilling (Contractor)
Address HCR Box 7090 Pahrump (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-10-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627