WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31008
Permit No. 51190
Basin

'NT OR TYPE ONLY

NOTICE OF INTENT NO. 5625

OWNER Pete La Pierre
MAILING ADDRESS c/o Stoddaard Bldg. Co., Inc.
2325 Western, Las Vegas, NV

ADDRESS AT WELL LOCATION Extreme east end of Copper Lane

2. LOCATION SW ¼ NE ¼ Sec. 35 T 20 ☒S R 62 E Clark County
PERMIT NO. 51190 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐ Quesi

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	60	60
Clay & boulders		60	120	60
Sandy clay		120	180	60
Clay & gravel		180	320	140
Br. sandy clay		320	360	40
Wh. sandy clay & grav.		360	380	20
White saandy clay		380	400	20
Wh. & br. clay & grav.		400	420	20
Hd. cem. gravel		420	440	20
Greenshale		440	460	20
Green & red shale		460	480	20

RECEIVED
JAN 12 1989
Div. of Water Resources
Branch Office Las Vegas, NV

Date started Dec. 23, 1988
Date completed Jan. 3, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 480 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 inches	+1 feet	385 feet
inches	380 feet	480 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 480 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½ 8 rows 6" centers
From 300 feet to 460 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 265 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. (Contractor)
Address 4185 W. Harmon, Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard K. Thompson Jr. (By driller performing actual drilling on site or contractor)
Date Jan. 9, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627